

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATENo. 738Dated : 20-07-26It is certified that an inspection team headed by KH. SHEELA - MOREE(Name of Officers with designation) from ASSISTANT ENGINEERDHAR
PHED inspected the **ACADEMIC HEIGHTS PUBLIC SCHOOL, DHAR, M.P.** on20-07-26 (date of inspection) and on the basis of Water Test Report (Attached)bearing no 235 dated 17-07-2026 ofDISTRICT WATER TESTING LAB(PHED Lab) certified that the **ACADEMIC HEIGHTS PUBLIC SCHOOL, DHAR, M.P.** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.This certificate is valid till 6 MONTHS
01 YEAR

Signature with Seal:


Assistant Engineer
P.H. Sub-Div. DHAR (M.P.)Name : KH. SHEELA MOREEDesignation : ASSITANT ENGINEERName & Address of the Office / Department : P.H.E. SUB DIVISIONDHAR (M.P.)

To,

ACADEMIC HEIGHTS PUBLIC SCHOOL,
DHAR, M.P.
PRESIDENT
VAAS EDUCATIONAL AND
SOCIAL WELFARE SOCIETY
PRINCIPAL
ACADEMIC HEIGHTS PUBLIC SCHOOL

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Water Testing Laboratory

P.H.E.Div. Dhar (M.P.)

phelabdhar@gmail.com

Water Testing ReportDWTL/Dhar No 235 dt 17/07/2026 Your Ref :- Nil dt 15.07.2026**Samples From : ACADEMIC HEIGHTS PUBLIC SCHOOL, DHAR****1) Water Sample from School**

Date of Reciept :- 15.07.2026

Date of Start of Analysis :- 15.07.2026

Date of Completion of Analysis :- 16.07.2026

Sample collected and submitted by the customer

S.No.	Parameters	Test method	BIS 10500:2012 Desirable/Permissible Limit and Unit	Result			
				Water Sample from School			
1	Colour	IS 3025 part 4	5/15 Co.Pt Scale	5			
2	Odour	IS 3025 part 5	Acceptable	Acceptable			
3	Turbidity	IS 3025 part 10	1.0/5.0 NTU	1.3			
4	pH	IS 3025 part 11	6.5 – 8.5 pH Scale	7.16			
5	Specific Conductivity	IS 3025 part 14	Micro mhos/cm	1106			
6	Total Dissolved Solids	IS 3025 part 16	500 / 2000 mg/Lit.	684			
7	Total Hardness (as CaCO ₃)	IS 3025 part 21	200 / 600 mg/Lit.	322			
8	Calcium	IS 3025 part 40	75 / 200 mg/Lit.	86.4			
9	Magnesium	IS 3025 part 46	30 / 100 mg/Lit.	25.4			
10	Sulphate (as SO ₄)	IS 3025 part 24	200 / 400 mg/Lit.	46			
11	Total Alkalinity	IS 3025 part 23	200 / 600 mg/Lit.	274			
12	Chlorides (as Cl)	IS 3025 part 32	250 / 1000 mg/Lit.	135			
13	Fluorides (as F)	IS 3025 part 60	1.0 / 1.5 mg/Lit.	0.34			
14	Nitrates (as NO ₃)	APHA 23 Edition 4500B UV	45/ 45 mg/Lit.	26			
15	Iron (as Fe)	IS 3025 part 53	1.0/1.0 mg/Lit.	0.2			
16	Manganese	IS 3025 part 59	0.1 / 0.3 mg/l	0			
17	Residual Chlorine	VCM	0.2 mg/Lit. at Consumer point				
18	Total Coliform	APHA 22 Edition 9211B	0 / 0	0			
19	Feacal Coliform	APHA 22 Edition 9211B	0/ 0	0			

Remarks:- All the tested parameters are with in the Permissible limits as per BIS 10500 - 2012 in the given sample.

Atsodhyg**PRINCIPAL****ACADEMIC HEIGHTS PUBLIC SCHOOL**Travisith**PRESIDENT****VAA EDUCATIONAL AND
SOCIAL WELFARE SOCIETY**

CHEMIST
Dist. Water Testing Laboratory
Dhar (M.P.)